

WAGNER SERVICECENTRUM Co. Ltd., Teslova 2, 040 12 Košice

| | |
|----------------------------------|-----------------|
| SK-Conformity declaration | C SK |
|----------------------------------|-----------------|

Undersigned representative

of producer : **WAGNER SERVICECENTRUM Co. Ltd., 040 12 Košice Teslova 2,**

of workshop: **Košice**

by this proclaims, that the product:

Steel profile for plasterboard profiles, for type, : WAGNER plasterboard profiles UDD 30

is in conformity with clause of the law num. 90/1998 of digest of laws about the constructional products as amended by the latter acts, if it is mounted in accordance with the technical condition of the product, the manual for the assembly, with declared use of the product and for the product are applied these norms:

STN EN 14195 : 2007 Metal sheets for base constructions of plasterboard systems

Within initial testing of type were certified:

| The Characteristics | Declared value or class | Protocol about testing and reference to laboratory |
|--------------------------------|---|--|
| Tolerance of parameters | Profile width $w = 28,3$ mm Width of flange $w_1 = 27,0$ mm Width of flange $w_2 = 27,1$ mm The angle between web plate and flange $a_1 = 89$ The angle between web plate and flange $a_2 = 90$ Flatness $= 1,00$ mm | Testing protocol num. 70-090023 from the day 12.02.2009 |
| Fold of loading | Average values 223/36/900 | Testing protocol num. 70-09-0031 from the day 26.2.2009 |

Product description:

Parameters: height 27 mm
 Width 28 mm

The title and adresses of laboratories, which accomplished tests:

1) TSUS, Studená 3, 821 04 Bratislava, testing workplace Krmanova 5, 040 00 Košice

The producer: **WAGNER SERVICECENTRUM Co. Ltd., Teslova 2, 040 12 Košice**

The name: **Róbert Wagner**

Status: **director**

Date: **01.04.2009**